

**SUPPLEMENT 1**

Wakulla Shadeville Elementary HVAC

Allstate Construction, Inc.  
September 12, 2024

**Engineer's Addendum**

1. Incorporate Addendum 1 dated September 12, 2024, prepared by H2 Engineering.

**HVAC Equipment**

2. The antimicrobial coating can be omitted from the inner liner on AHU-8.1 and AHU-8.2 if needed to allow for the manufacturer's quick-ship option.

END OF SUPPLEMENT