

Addendum #04

Date: 11-18-2024
Project: Gulf Coast Rehabilitation Center (GCRC)
From: J. Barrett Penney, AIA
To: All Bidders
Via: Email

This addendum shall be considered part of the bid documents for the above-mentioned project. Where provisions of this following supplementary data differ from those of the original bid documents, this Addendum shall govern and take precedence. Bidders shall acknowledge this Addendum on the Form of Proposal.

ITEM No. 01: Refer to the revised Civil Drawings, dated 11-15-24 provided by the owner and included with the addendum.

ITEM No. 02: Clarification: The general contractor shall provide a new Building Automation System 'BAS' for the HVAC controls. System is to be equal to Honeywell or Siemens. Refer to the project specifications, section 23 09 00 'Instrumentation and Control for HVAC', section 1.3 'Description of System', paragraph F.

Foshee Architecture
21 S. Court Street
Montgomery, AL 36104