



ADDENDUM NO. 1

RAA MIDDLE SCHOOL DINING EXPANSION PROJECT
401 W Tharpe Street
Tallahassee, FL 32399
LCS 10-24-B-223

FOR: LEON COUNTY SCHOOLS

April 18, 2025

This Addendum forms a part of the contract documents and modifies the drawings and specifications dated April 2, 2025, as noted below. Acknowledge receipt of this Addendum on the proposal form in the space allocated. Failure to do so may subject Bidder to disqualification.

ITEM NO. 1: SPECIFICATIONS, SECTION 07 41 00 - METAL ROOF AND FASCIA PANELS:

Change: 2.2, A, 2 – Roof panel thickness shall be 24 gauge.

ITEM NO. 2: DRAWINGS, SHEET A000, FINISH SCHEDULE NOTES:

Change: Add at the end of note regarding LVT substitute:

VCT - ARMSTRONG, EXCELON - COLORS TO BE DETERMINED
BASE BID: EXISTING TO REMAIN; REPLICATE EXISTING FLOORING PATTERN IN
ADDITION.
ADDITIVE ALTERNATES 1 & 6: SEE FLOORING PLAN FOR INSTALLATION PATTERN.
ADDITIVE ALTERNATE 6 - SUBSTITUTE FOR LVT – MANNINGTON, COLOR
ANCHOR, STRIDE, 6"X36", COLORS TO BE SELECTED

ATTACHMENTS: None

COPIES TO: Owner, Contractor

END OF ADDENDUM NO. 1